Thomas@Betts



Representative

 Catalog Number:
 \$503-K0.3

 UPC Number:
 80432589686

Status: Active

Miniature Circuit Breaker, Supplemental Protector, Rated Current 0.3 Amps, 3 Pole, Interrupt Rating 30 kA, Thermal Magnetic Trip Curve K, Electromechanic and/or Thermal Tripping Mechanism for Short Circuit Protection, Voltage up to 277/Y600 VAC (UL 1077) and 690 VAC (IEC), DIN Rail Mounted, Finger Safe and Multi-Function Terminals, CSA 22.2

| North American Specifications (UNSPSC) | |
|--|--|
| UNSPSC | 39121603 Miniature circuit breakers |
| IGCC | 4897 Miniature circuit breakers |
| Brand Name | ABB |
| | |
| Туре | High Performance MCB Provides Compact Supple- mentary, Energy Limiting, Circuit Protection |
| Special Features | DIN Rail Mounting, Finger Safe and Multi-Function Terminals |
| Application | Designed for Allowing Higher In-Rush Current During System Start Up; Example: Motors, Transformers |
| Standard | UL 1077, CSA 22.2 No. 235, VDE 0641/6.78 |
| Voltage Rating | 277/Y600 VAC (UL1077), 690 VAC (IEC) |
| Amperage Rating | 0.3 Amps |
| Frequency Rating | 50/60 Hertz |
| Trip Type | K |
| Interrupt Rating | 30 kA |
| Number Of Poles | 3 |
| Auxiliary Contacts | Yes |
| Length | 86 mm |
| Width | 75 mm |
| Height | 92 mm |
| Operating Temperature | -40 Degrees Celcius |
| Packaging | |
| Outer Quantity | 1 |
| Outer Dimensions (inches) | 3.75x3.75x3 |
| Weight Uom | 1.51 lbs. Each |

For further technical assistance, please contact us...

T&B Technical Support MS 3B-50 860 Ridge Lake Blvd. Memphis, TN 38120 Hours: 7AM - 6PM CDT Monday-Friday Phone: (888) 862-3289 Fax: (901) 252-1321 Email:techsupport@tnb.com

Thomas & Betts - USA 860 Ridge Lake Blvd. Memphis, TN 38120 www.tnb.com